



# UNH IOL PCIe Consortium

## PCIe Gen 3 CEM Receiver Testing

InterOperability Lab — 121 Technology Drive, Suite 2 — Durham, NH 03824 — (603) 862-0701

January 24, 2014

Mr. Vendor  
Company Name  
Address

Mr. Vendor:

Enclosed are the results from the PCIe Gen 3 CEM Receiver testing performed on the:

20140106 UNHID Company DUT PCIe Gen 3 Platform/AIC

The testing was performed according to Version 0.91 of the PCI Sig, PCI Express 3.0 CEM RX Physical Layer Test Method of Implementation for Agilent J-BERT N4903B High Performance Serial BERT, which is available online at:

[http://www.pcisig.com/members/downloads/specifications/Agilent PCIe 3.0 8G RX MOI v0 91.pdf](http://www.pcisig.com/members/downloads/specifications/Agilent_PCIe_3.0_8G_RX_MOI_v0_91.pdf)

Note that the tests defined in this test suite are based on:

*PCI Express Base Specification Revision 3.0, version 1.0*

*PCI Express Card Electromechanical Specification Revision 3.0, version 0.9*

*PCI Express® Architecture PHY Test Specification Revision 3.0, Ver. 0.9*

Please feel free to contact me at [jbeaudet@iol.unh.edu](mailto:jbeaudet@iol.unh.edu) if you have any questions regarding the test suite, or the results contained in this report.

Sincerely,

Joshua Beaudet


### **Digital Signature Information**

This document was created using an Adobe digital signature. A digital signature helps to ensure the authenticity of the document, but only in this digital format. For information on how to verify the integrity of this document, please proceed to the following site:

<http://www.iol.unh.edu/certifyDoc/>

If, after following the steps indicated above, the document status still indicates “Validity of author NOT confirmed”, please contact the UNH-IOL to confirm the document’s authenticity. To further validate the certificate integrity, Adobe 6.0 should report the following fingerprint information:

MD5 Fingerprint (2014): 41 1E 00 9F 79 4D 02 EF E6 95 65 57 A4 71 4F 9F  
SHA-1 Fingerprint (2014): 44 51 9E 22 66 59 1A D3 A1 F9 0B EE BD 01 90 80 BE 61 A4 A8



**Table 1: Test Equipment and DUT Configuration/Feature Information**

DUT Details	
Manufacturer	
Model	
Device Type (Platform/AIC)	
Mfr. Serial Number	
BIOS Version	
Hardware Version	
Software Version	
UNH-IOL ID Number	
Processor Details (If applicable)	
Spec	
Lot Information	
Manufacture Location	
Lot Numbers	
Test System Hardware	
Real-time DSO (for Calibration)	Agilent Infiniium DSO91304A, 13GHz, 40GS/s Real-time DSO
Bit Error Tester/ Pattern Generator	Agilent J-BERT N4903B, 12.5Gb/s, High Performance Serial BERT
De-Emphasis Box	Agilent N4916B De-Emphasis Signal Converter
Clock Multiplier	Agilent N4880A Reference Clock Multiplier
Repeater	National Semiconductor/TI DS80PCIEVK REV.1
Test Fixture	PCI Sig PCIe x16 Compliance Load Board
Additional Comments/Notes	
<p>The testing was performed without the Repeater as it was not needed.</p>	

**Figure 1: Test Setup**

Note: The Reference Clock Multiplier is not pictured. That box takes the clock from the CLB and puts out a reference clock that feeds the clock in on the Error Detector of the J-BERT.




Table 2: Test Results

Slot	Lane	Errors	Bit Count	BER	Result
1	0	0	3.01681692E12	0	Pass
1	7	0	3.01649533E12	0	Pass
1	15	0	3.01631390E12	0	Pass
2	0	0	3.01679100E12	0	Pass
2	7	0	3.01725552E12	0	Pass
2	15	0	3.01705414E12	0	Pass
3	0	0	3.01382083E12	0	Pass
3	7	0	3.01422731E12	0	Pass
3	15	0	3.01409973E12	0	Pass
4	0	0	3.01335704E12	0	Pass
4	7	0	3.01332195E12	0	Pass
4	15	0	3.01333870E12	0	Pass
5	0	0	3.01644679E12	0	Pass
5	7	0	3.01644679E12	0	Pass
5	15	0	3.01421346E12	0	Pass
6	0	0	3.01372464E12	0	Pass
6	7	2	3.01357117E12	6.6366E-13	Pass
6	15	0	3.01369993E12	0	Pass
7	0	0	3.01103704E12	0	Pass
7	7	0	3.01402182E12	0	Pass
7	15	0	3.01409973E12	0	Pass
8	0	0	3.01304817E12	0	Pass
8	7	0	3.01304918E12	0	Pass
8	15	4	3.01304727E12	1.3276E-6	Fail

